



NOTES:

1. All dimensions are in millimetres unless otherwise stated.
2. Cables shall be labelled as required.
3. All gland terminations are as Drg No **SD/1400/7**.
4. Switchgear to have voltage warning labels and isolators to have ID labels.
5. Labelling to be in compliance with IET wiring regulations, see Drg No **SD/1400/10** for examples.
6. Internal detail of Feeder Pillar is an indicative layout only.



©Crown copyright 2015. All rights reserved. Use of this image is limited to viewing on-line and printing one copy. Leicestershire County Council. 100019271.



ENVIRONMENT AND
TRANSPORT DEPARTMENT

TITLE:

STREET LIGHTING

FEEDER PILLAR DETAIL - TYPE 3

DRAWING NUMBER

SD/1400/05

DATE

APRIL 2024

AUTOCAD REF

K:\GENERAL\ID9997\STDORG\STD DRGS 2015

SCALE

NOT TO SCALE

0

Rev

01.04.2024

Date

Supersedes Dwg. SD/14/5 - September 2002

Notes on Revision